

Storage - Part III



- **System Storage**
 - Good Quality Water
 - Match Supply & Demand
 - Adverse Weather
- **Reject Storage**
 - Bad Quality Water
 - Operating Protocol
- **Alternative Discharge Provides Flexibility**



System Storage

- **Capacity**
 - 10-year Recurrence Interval
 - “LANDAP”
 - Rule 62-610.414, F.A.C.
 - Normally About 15 days
 - Minimum 3 days
- **May be Unlined**
- **Lakes & Ponds**
- **Re-treatment is Optional**
- **Residual Not Required in Distribution System**



Reject Storage

- **Operating Protocol**
- **Capacity 1 day**
- **Lined**
- **Recycle for Re-treatment**

